


## Health & Hygiene Certificate


Ref. No. CS/Pwl/2024/SHH/36

Dated. 19/06/2024

In pursuance of the application Ch. Heera Lal Memorial Sr. Sec. School, Chhajjunagar, Palwal (Haryana) in the O/o Civil Surgeon, Palwal. The School premises were inspected by team of Health Department O/o Civil Surgeon, Palwal on dated 14-06-2024. The School was found to have satisfactory hygiene conditions as per the standard checklist of the district. This certificate is valid up to 31-03-2025.

Date of Renewal:- 01-04-2025

  
Civil Surgeon  
Palwal

1  
Remeshwar 19/6/2024  
Dy. Civil Surgeon (School Health)  
Palwal 



# OFFICE OF THE CHEMIST

PUBLIC HEALTH ENGINEERING DEPARTMENT DRINKING WATER TESTING LABORATORY, PALWAL  
9MLD STP, JODHPUR ROAD, PALWAL, HARYANA - 121102

E-mail:-chemist.palwal@phedharyana.gov.in, chemist.palwal@gmail.com

**PHED**  
Haryana

## TEST REPORT

Issued to : → Ch. Heera Lal Memorial Sr. Sec. School	Location: → Chhajju Nagar, Palwal
Test Report No. : → PWL/01187/6/2024	Collected by: → Gulshan Lal
Reference No. : → 989 /dt. 05/05/2024	Sample collected Date & Time : → 13/06/2024 at 10:30
Sample Type : → Submersible	Sample received Date & Time: → 13/06/2024 at 12:12
Test Type : → Chemical Test	Date of Analysis Started : → 13/06/2024
Classification of Sample : → Private	Date of Analysis Completed : → 13/06/2024
Sample Description : → Water Sample Received in food grade plastic bottle at room temperature	Sample Quantity : → 1000 ml
Lab Job Order No.: → V-330	Issue Date of Report: - 20/06/2024
	Addition/Deviation/ Exclusions from the method :- NA

## Test Result

Sr. No.	Tested Parameter	Results	Unit	Method	As per IS 10500:2012 RA 2018	
					Acceptable	Permissible Limit
1.	Turbidity	<1	NTU	APHA 24th Edition-2130-B	1 NTU	5 NTU
2.	Taste	Agreeable		IS 3025 (Part-8)1984:RA 2023	Agreeable	Agreeable
3.	Odour	Agreeable		IS 3025 (Part-5) 1983:2018	Agreeable	Agreeable
4.	Colour	<5	CU	APHA 24th Edition-2120 - B	5 CU	15 CU
5.	Total Dissolve Solids (180°C ± 2°C)	1370	mg/l	APHA 24th Edition-2540 C	500 mg/l	2000 mg/l
6.	Total Hardness as CaCO <sub>3</sub>	400	mg/l	APHA 24th Edition-2340 C	200 mg/l	600 mg/l
7.	Calcium as (Ca)	84.16	mg/l	APHA 24th Edition-3500-Ca B	75 mg/l	200 mg/l
8.	Magnesium (Mg)	46.17	mg/l	APHA 24th Edition-3500Mg B	30 mg/l	100 mg/l
9.	Total Alkalinity	350	mg/l	APHA 24th Edition-2320 B	200 mg/l	600 mg/l
10.	Chlorides as Cl	269.91	mg/l	APHA 24th Edition-4500 Cl- B	250 mg/l	1000 mg/l
11.	Sulphate as (SO <sub>4</sub> )	100	mg/l	APHA 24th Edition-4500-SO <sub>4</sub> <sup>2-</sup> E	200 mg/l	400 mg/l
12.	Fluoride as (F)	0.54	mg/l	APHA 24th Edition-4500-F- D	1.0 mg/l	1.5 mg/l
13.	Iron as (Fe)	0.09	mg/l	APHA 24th Edition-3500-Fe B	1.0 mg/l	No Relaxation
14.	Nitrate as (NO <sub>3</sub> )	4.3	mg/l	APHA 24th Edition-4500-NO <sub>3</sub> - D	45 mg/l	No Relaxation
15.	pH (@25°C)	6.74	---	APHA 24th Edition-4500-H+ B	6.5-8.5	No Relaxation

### Remarks: -

#### Specific contractual notes: -

- ♦ The results given above are related to the sample as received and tested in PHED Lab PALWAL.
- ♦ The test report can't be regenerated/ re-produced in whole or part thereof without written permission of PHED Lab PALWAL.
- ♦ The test report can't be used for any publicity or any legal purpose.
- ♦ Reliability of water sample lies with sender/collector of water sample.

CHEMIST (REENA)  
PUBLIC HEALTH ENGINEERING DEPARTMENT  
WATER TESTING LABORATORY  
PALWAL

END OF REPORT